

SANITARY SEWER GENERAL NOTES:

MATERIALS - PIPE:

(1) ASTM D3034 PVC GRAVITY SEWER MAIN PIPE - GASKETED JOINTS - SDR35 STANDARD

MATERIALS - JOINTS/FITTINGS:

(1) ASTM F1336 GASKETED PVC SEWER FITTINGS
 (2) AMERICAN MADE DUCTILE IRON FITTINGS W/ CEMENT LINING & RESTRAINTS

NOTES:

(1) CONTRACTOR RESPONSIBLE FOR VERIFYING, BEFORE CONSTRUCTION, THAT THE LATEST STANDARD DETAILS ARE BEING USED, AS POSTED ON THE ELLICOTTVILLE ENGINEERING WEBSITE.

(2) ALL WORK IS TO BE COMPLETED IN ACCORDANCE WITH NYSDOH, LOCAL DOH, NYSDOT, OSHA, AND TOWN/VILLAGE REQUIREMENTS.

(3) ALL EXISTING UTILITY LINES AND SERVICE LATERALS NEAR OR CROSSING THE NEW SEWER MAIN SHALL BE PROTECTED, PRESERVED, AND SUPPORTED AS NECESSARY.

(4) HIGHWAY DRAINAGE SHALL BE MAINTAINED THROUGHOUT THE PERIOD OF CONSTRUCTION. THE ROADS SHALL BE KEPT CLEAN OF MUD AND DEBRIS AT ALL TIMES. CONTRACTOR RESPONSIBLE FOR ANY DAMAGE TO HIGHWAYS.

(5) SAFE AND CONTINUOUS THROUGH TRAFFIC AND INGRESS AND EGRESS FOR ADJACENT DRIVEWAYS, SERVICE ROADS, AND PUBLIC STREETS SHALL BE MAINTAINED THROUGHOUT THE PERIOD OF CONSTRUCTION.

(6) THE OWNER WILL OBTAIN ALL NECESSARY EASEMENTS OR PERMITS.

(7) THE CONTRACTOR SHALL LOCATE, FLAG AND PRESERVE SURVEY MONUMENTS AND PROPERTY CORNER MARKERS. THE CONTRACTOR SHALL HAVE A LICENSED SURVEYOR RE-ESTABLISH ANY PROPERTY CORNERS OR SURVEY MONUMENTS DISTURBED DURING CONSTRUCTION.

(8) MINIMUM VERTICAL SEPARATION BETWEEN WATER MAINS AND SEWER LINES SHALL BE 18 INCHES MEASURED FROM THE OUTSIDE OF THE PIPE AT THE POINT OF CROSSING. MINIMUM HORIZONTAL SEPARATION PARALLEL WATER MAINS AND SEWER PIPE (INCLUDING MANHOLES AND VALVES) SHALL BE 10 FEET MEASURED FROM THE OUTSIDE OF THE PIPES. MANHOLES OR VALVES. ONE FULL STANDARD LAYING LENGTH OF WATER MAIN SHALL BE CENTERED UNDER OR OVER THE SEWER SO THAT BOTH JOINTS WILL BE AS FAR FROM THE SEWER AS POSSIBLE. IN ADDITION, WHEN THE WATER MAIN PASSES UNDER THE SEWER, ADEQUATE STRUCTURAL SUPPORT (COMPACTED SELECTED FILL) SHALL BE PROVIDED FOR THE SEWER TO PREVENT EXCESSIVE DEFLECTION OF THE JOINTS AND SETTLING TO THE SEWER ON THE WATER MAIN.

(9) THE CONTRACTOR SHALL BE RESPONSIBLE FOR ALL DAMAGE TO EXISTING PUBLIC AND PRIVATE ROADWAYS, PAVEMENT, LAWN AREAS, TREES, UTILITIES, STRUCTURES, SIGNS, AND OTHER EXISTING FEATURES CAUSED BY CONSTRUCTION OPERATIONS. ALL SUCH DAMAGE SHALL BE REPAIRED OR REPLACED IN KIND BY THE CONTRACTOR.

(10) HIGHWAY SUBGRADE SHALL BE PROTECTED USING SHEET PILES WHERE THE MANHOLES ARE LESS THAN 1' FROM THE ROAD SHOULDER.

(11) ALL CONCRETE SIDEWALKS CROSSED BY THE SEWER MAIN INSTALLATION SHALL BE SAW CUT.

(12) A CRITICAL RESPONSIBILITY OF THE CONTRACTOR: EROSION CONTROL DEVICES SHALL BE ESTABLISHED PRIOR TO COMMENCING WORK.

(13) ALL EXISTING UTILITY LINES AND SERVICE LATERALS NEAR OR CROSSING THE NEW SEWER MAIN SHALL BE PROTECTED, PRESERVED AND SUPPORTED AS NECESSARY.

(14) UTILITY POLES SHALL BE SUPPORTED WHERE NECESSARY.

(15) CONTRACTOR SHALL PRESERVE AND PROTECT FROM DAMAGE ALL TREES, FENCES AND OTHER OBSTACLES WITHIN THE RIGHT OF WAY AND EASEMENT, WHEN IN PROXIMITY OF TREES, DRILL UNDER TREES.

(16) PROTECTION OF NEW OR EXISTING WORK SHEETING OR SHORING, IF REQUIRED DURING CONSTRUCTION, SHALL BE PROVIDED.

(17) WHEREVER MAILBOXES, POSTS, FENCES, SHRUBBERY ETC. ARE IN CONFLICT WITH THE PROPOSED CONSTRUCTION, THEY SHALL BE REMOVED AND RESET AS NECESSARY.

(18) CONTRACTOR SHALL BE RESPONSIBLE FOR PROPER DISPOSAL OF EXCAVATED MATERIAL FROM THE SITE.

(19) THE CONTRACTOR SHALL CONFORM TO ALL CONDITIONS OF ANY APPLICABLE EASEMENTS.

(20) THE CONTROL OF DUST ORIGINATING FROM THE CONSTRUCTION OPERATIONS IS CONSIDERED A CRITICAL RESPONSIBILITY OF THE CONTRACTOR. THE WATER SYSTEM OPERATOR WILL BE THE FINAL JUDGE OF THE ADEQUACY OF THE CONTRACTOR'S DUST CONTROL EFFORTS, AND WORK MAY BE SUSPENDED BY THE TOWN UNTIL ADEQUATE DUST CONTROL IS ATTAINED.

(21) THE CONTRACTOR SHALL PERFORM SEWER MAIN LEAKAGE TESTING IN ACCORDANCE WITH ASTM STANDARD F1417-98 AND UBPPA-UNI-B-6-98.

(22) THE CONTRACTOR SHALL PERFORM MANHOLE LEAKAGE TESTING IN ACCORDANCE WITH ASTM STANDARD C1244-11.

REVISIONS	
DATE	COMMENTS

ISSUE DATE: SEPTEMBER 2018

SEWER - S-05

TOWN & VILLAGE OF ELLICOTTVILLE

EVL ENG DEPT.

