



WATER SERVICE DETAIL – MAIN TO CURB BOX

N.T.S.

CURB BOX MARKED "WATER" SLIDING WITH STAINLESS STEEL ROD

ROW OR EASEMENT LINE

CURB BOX TO BE SET 2" BELOW GRADE SURFACE

- GENERAL NOTES
1. STAINLESS STEEL INSERTS SHALL BE USED AT ALL HDPE CONNECTIONS.
 2. TRACER WIRE SHALL BE PLACED ALONG ENTIRE LENGTH OF SERVICE LINE & BE ACCESSIBLE IN CURB BOX.

STANDARDS

1. AWWA C901
2. AWWA C800

MANUFACTURER

1. A.Y. MCONALD

ISSUE DATE: SEPTEMBER 2018

TOWN & VILLAGE OF ELLICOTTVILLE

REVISIONS	DATE	COMMENTS

EVL ENG DEPT.

WATER - W-03

