



WATER SERVICE DETAIL – CURB BOX TO CUSTOMER

N.T.S.

1. STAINLESS STEEL INSERTS SHALL BE USED AT ALL HDPE CONNECTIONS.
2. TRACER WIRE SHALL BE PLACED ALONG ENTIRE LENGTH OF SERVICE LINE FROM THE CURB BOX TO THE BASEMENT OR CRAWL SPACE.
3. THE INTERNAL PLUMBING SYSTEM SHALL BE PROTECTED FROM PRESSURE SURGES, THERMAL EXPANSION, HYDRAULIC SHOCK, AND FREEZING PER NYS PLUMBING CODE. MAINTENANCE OF THE WATER SERVICE FROM THE CURB BOX TO AND INCLUDING THE INTERNAL PLUMBING ON PREMISES, AND ITS USE, MUST ALWAYS BE KEPT IN FULL COMPLIANCE. THE TOWN AND VILLAGE'S RESPONSIBILITY ENDS AT THE CURB BOX.
5. THE CUSTOMER MUST ACQUIRE A BUILDING PERMIT AND SUBMIT A WATER TAP APPLICATION FROM THE BUILDING INSPECTOR. INSPECTIONS MUST BE SCHEDULED WITH THE ENGINEERING DEPARTMENT PRIOR TO BACKFILLING.

STANDARDS

1. AWWA C901
2. AWWA C800
3. NSF/ANSI 61

MANUFACTURER

1. FITTINGS, VALVES, SADDLES – AY MCDONALD
2. METER – BADGER

GENERAL NOTES

ISSUE DATE: SEPTEMBER 2018

TOWN & VILLAGE OF ELLICOTTVILLE

REVISIONS	DATE	COMMENTS

EVL ENG DEPT.

WATER - W-04

